Dual PID auto tuning control


Features

- Dual PID auto tuning function:
 High-speed response of PID control to reach to the
 - desired value fast, low-speed of response of PID control to minimize the overshoot even though response is a little bit slow.
- High display accuracy: ±0.3%(by F.S. value of each input)
- · 2-Steps auto tuning control function
- Multi-input function
 (13 kinds of multi-input selection function):

 Temperature sensor, voltage and current selection function.
- Various sub output function: Includes in LBA, SBA, 7 kinds of alarm output and 4 kinds of alarm option function, PV transmission output(DC4-20mA), RS485 communication output
- Display the decimal point for analog input










Ordering information



%1: Only for TZ4SP, TZ4ST, TZ4L, TZN4M Series.

H-72 Autonics

Specifications

Series		TZ4SP TZN4S	TZ4ST	TZ4M TZN4M	TZ4W TZN4W	TZ4H TZN4H	TZ4L TZN4L		
Power	AC Power	100-240VAC 50/6	0Hz		•				
supply	AC/DC Power ^{*1}	24VAC 50/60Hz /	24-48VDC						
Allowable	voltage range	90 to 110% of rate	ed voltage						
Power con	_ AC Power	Max. 5VA(100-24	0VAC 50/60Hz)	Max. 6VA(100-24	0VAC 50/60Hz)				
sumption	AC/DC Power ^{*1}	Max. 8VA(24VAC	50/60Hz), Max. 7	W(24-48VDC)					
Display ac	curacy	,	d, SV: green) LED						
	size(W×H)	TZ4SP: 4.8×7.8mm TZN4S: PV:7.8×11.0mm	4.8×7.8mm	TZ4M: PV:9.8×14.2mm SV:8.0×10.0mm TZN4M: PV:8.0×13.0mm	8.0×10.0mm	TZ4H: 3.8×7.6mm TZN4H: PV:7.8×11.0mm	PV:9.8×14.2mm SV:8.0×10.0mm		
		SV:5.8×8.0mm		SV:5.0×9.0mm		SV:5.8×8.0mm			
	RTD	DPt100Ω, JPt100	Ω, 3wire(allowable	line resistance ma	ax. 5Ω per a wire)				
Input	Thermocouple	K(CA), J(IC), R(P	R), E(CR), T(CC),	S(PR), N(NN), W(TT)(allowable line	resistance max. 10	ΙΟΩ)		
type	Analog	1-5VDC, 0-10VD0	C, DC4-20mA	·					
	Relay	250VAC 3A 1c							
Control output	SSR	12VDC ±3V 30m/	A Max.						
Jaipat	Current	DC4-20mA(load 6	600Ω Max.)						
	PV transmission								
Sub	EVENT1	250VAC 1A 1a							
output	EVENT2	_	250VAC 1A 1a						
	Communication	RS485(PV/SV transmission, SV setting)							
Control typ	oe	ON/OFF, P, PI, PD, PIDF, PIDS control							
Display accuracy		F.S. ±0.3% or 3°C, select the higher one							
Setting method		Front push buttons							
Hysteresis	i	1~100°C(0.1 to 100.0°C) variable(ON/OFF control)							
ALARM ou	ıtput	Adjustable ON/OFF 1 to 100(0.1 to 100.0)°C of alarm output							
Proportion	al band(P)	0.0 to 100.0%							
 Integral tim	ne(I)	0 to 3600 sec.							
Derivative	time(D)	0 to 3600 sec.							
Control pe	riod(T)	1 to 120 sec.							
Sampling p	period	0.5 sec.							
LBA setting		1 to 999 sec.							
RAMP sett	ting	Ramp Up, Ramp	Down at 1 to 99mi	n.					
Dielectric s	strength	2,000VAC 50/60H	z for 1min.(between	en power source te	rminal and input	erminal)			
Vibration		0.75mm amplitude at frequency of 10 to 55Hz(for 1min.) in each of X, Y, Z direction for 2 hours							
Relay	Main output	Mechanical: Min. 10,000,000 operations, Electrical: Min. 100,000 operations(250VAC 3A resistive load)							
life cycle	Sub output	Mechanical: Min.	20,000,000 operat	tions, Electrical: Mi	n. 500,000 operat	ions(250VAC 1A re	sistive load)		
Insulation i	resistance	Min. 100M Ω (at 500VDC megger)							
Noise resis	stance	±2kV the square wave noise(pulse width: 1us) by the noise simulator							
Memory retention		Approx. 10 years(when using non-v	olatile semiconduc	tor memory type)	,			
Environ- Ambient temperature Ambient humidity		-10 to 50°C, stora	ge: -20 to 60°C						
		35 to 85%RH, sto		H					
Approval	<u> </u>	(E : FL us							
Unit weight		TZ4SP: Approx. 136g TZN4S:	Approx. 136g	Approx. 270g	TZ4W: Approx. 270g TZN4W:	Approx. 259g	Approx. 360g		

X1. AC/DC power type is only for TZ4SP, TZ4ST, TZN4M, TZ4L Series.

(M) Tacho/ Speed/ Pulse meter (N) Display unit (P) Switching mode power supply (Q) Stepper motor& Driver&Contro (T) Software H-73


Autonics

XEnvironment resistance is rated at no freezing or condensation.


TZN/TZ Series

Connections


%RTD: DPt100 Ω (3-wire type), JPt100 Ω (3-wire type) %T.C(Thermocouple): K, J, R, E, T, S, W, N %In case of Analog input, please use T.C(Thermocouple) terminal and be careful about polarity.




MAIN OUT				
SSR	Current			
3	3			
12VDC ±3V 30mA Max.	DC4-20mA Load 600Ω Max.			




MAIN	OUT
SSR	Current
7 0	7 6
12VDC ±3V 30mA Max.	DC4-20mA Load 600Ω Max.



MAIN OUT					
SSR	Current				
9 - 0	9 - mA				
12VDC ±3V 30mA Max.	DC4-20mA Load 600Ω Max.				




MA	MAIN OUT		
SSR	Current	PV transmission output	
12 - 13 V	12 - 13 -	5 + mA	
12VDC ±3V 30mA Max.	DC4-20mA Load 600Ω Max.	DC4-20mA Load 600Ω Max.	



MAIN OUT				
SSR	Current			
13 -	13 12 +			
12VDC ±3V 30mA Max.	DC4-20mA Load 600Ω Max.			


H-74




Autonics


H-75





**Because TZ4SP uses same identification plate with TZ4ST, the indicator does not work even though it has a EV2 output signal indicator.





H-76 Autonics


• TZ4L


• TZN4L

• Panel cut-out










Parts description


• TZN4S



TZ4ST/TZ4SP



TZ4M



- 1: Display Processing value(PV)(Red)
- 2: Display Setting value(SV)(Green)
- 3: SV2 operation indicator
- 4: Auto-tuning indicator
- 5: Mode key
- 6: Auto-tuning operation key
- 7: Setting keys
- 8: Control output operation indicator

9: EVENT 1 output indicator 10: EVENT 2 output indicator

11: Procedure of setting key

**Because TZ4SP uses same identification plate with TZ4ST, the indicator does not work even though it has a EV2 output signal indicator.

**There are no(">>. ▶) Key in TZ4SP/TZ4ST/TZ4H/TZ4W and TZN4S/TZN4H/TZN4W.

*Control output indicator(OUT) does not work when it is used as current output type


SV setting



Press any key among **((**) key in RUN mode, the right digit at SV display flashes and it enters to SV setting.



$$(10^{0} \rightarrow 10^{1} \rightarrow 10^{2} \rightarrow 10^{3} \rightarrow 10^{0})$$



Press \checkmark (\triangle), \curvearrowright (\bigcirc) key to move the desired number(1 \rightarrow 5).



Press MD key to save the value and it controls with this set value.

※Above explanations are the example of TZ4M. In case of TZ Series. Use the Key in brackets for setting(changing). There are no ≫,(►) Key in TZN4S, TZ4SP and TZ4ST. It is not used for setting or changing the setting value. (A) Photo electric sensor (B) Fiber optic sensor

(C) Door/Area

> (D) Proximity

(E) Pressure sensor

> (F) Rotary

(G) Connector/



(I) SSR/ Power controller

(J) Counter

(K) Timer

> Panel meter

(M) Tacho/ Speed/ Pulse meter

(N) Display unit

Sensor controller

(P) Switching mode power supply

(Q) Stepper motor& Driver&Controller


(R) Graphic/ Logic panel

(S) Field network device

(T)

(U) Other

■ Flow chart for parameter 1 group



※Press ((x)) key and the right digit of SV display part flashes. Press ((x)) key and move to the desired digit.

Press ♠(♠), ▼(♦) keys to change SV and press MD key to complete the set. Press MD key again and it moves to next parameter.


XAfter completing setting at each parameter, press MD key for 3 sec. and it returns to RUN mode.

XIf no key touched for 60sec., it will return to RUN mode automatically.

Factory defaults(Parameter 1 group)

Parameter	Factory default						
5u-2	0	RHY5	2	Ŀ	20	r A P U	10
ALI	10	Ρ	3.0	H95	2	r RP d	10
AL2	10	1	0	In-b	0	LoC	oFF
LbA	600	В	0	r E S E	0.0		

H-78 Autonics



 \mathbb{Z} Press $\mathbb{Z}(\mathbb{Z})$ key and the right digit of SV display part flashes. Press $\mathbb{Z}(\mathbb{Z})$ or $\mathbb{Z}(\mathbb{Z})$ key and move to the desired digit.

Press ▲(♠), ▼(♦) keys to change SV and press MD key to complete the set. Press MD key again and it moves to next parameter.

**After completing setting at each parameter, press MD key for 3 sec. and it returns to RUN mode.

XIf no key touched for 60sec., it will return to RUN mode automatically.

※1: It may not be displayed by input type switch.

X2: This is displayed only for model with High/Low-limit of transmission output.

■ Factory defaults(Parameter 2 group)

Parameter	Factory default						
In-E	LC U'H	AL-E	AL-A	PIdE	PI d.5	H-5C	1300
EU-I	AL-I	A L.L	Eun I	o-Ft	HERL	L-5C	- 100
E U - 2	AL-5	rAñP	oFF	Uni E	٥.	LoC	oFF

Autonics H-79

(A) Photo electric sensor

> (B) Fiber optic sensor

(C) Door/Area sensor

(D) Proximity sensor

(E) Pressure sensor

(F) Rotary encoder

(G) Connector/

(H) Temp. controller

(I) SSR/ Power controller

(J) Counter

> () imer

Panel meter

(M) Tacho/ Speed/ Pulse meter

(N) Display unit

O) Sensor

(P) Switching

Switching mode power supply

Stepper motor& Driver&Controller

(R) Graphic/ Logic panel

(S) Field network device

> T) Software


(U) Other

TZN/TZ Series

■ Input type and range

Input type		Display	Input range(°C)	Input range(°F)
	K(CA) H	EC R.H	-100 to 1300	-148 to 2372
	K(CA) L	F.C.R.L	-100.0 to 999.9	Cannot be used
	J(IC) H	JI C.H	0 to 800	32 to 1472
	J(IC) L	JI C.L	0.0 to 800.0	Cannot be used
	R(PR)	r Pr	0 to 1700	32 to 3092
Thermonounle	E(CR) H	ECr.H	0 to 800	32 to 1472
Thermocouple	E(CR) L	ECr.L	0.0~800.0	Cannot be used
	T(CC) H	E C C.H	-200 to 400	-328 to 752
	T(CC) L	E C C.L	-199.9 to 400.0	Cannot be used
	S(PR)	5 Pr	0 to 1700	32 to 3092
	N(NN)	Поо	0 to 1300	32 to 2372
	W(TT)	UEE	0 to 2300	32 to 4172
	JPt100Ω H	JPE.H	0 to 500	32 to 932
DTD	JPt100Ω L	JPE.L	-199.9 to 199.9	-199.9 to 391.8
RTD	DPt100Ω H	dPt.H	0 to 500	32 to 932
	DPt100Ω L	dPt.L	-199.9 to 199.9	-199.9 to 391.8
	0-10VDC	A1	-1999 to 9999	-1999 to 9999
Analog input	1-5VDC	R2	-1999 to 9999	
	DC4-20mmA	A3	(display range depends o	n the decimal point position)

■ Input type switch



 $[\]ensuremath{\mathbb{X}}$ Factory default of input type switch: Temperature sensor input.

H-80 Autonics

XPlease select B) or C) according to input specification when it is voltage or current.

Alarm

This unit has output for control and sub(alarm) output. Sub output is optional. (This alarm output is relay contact(1a) and operates regardless of output for control.) Alarm output operates when the temperature of target is getting higher or lower than setting value.

- Select one among 6 alarm operations [AL 1/2/3/4/5/6] of event 1, 2[EU-1, EU-2] at parameter 2 group and set alarm temperature(deviation or absolute temperature) in AL1, AL2 alarm temperature[AL 1, AL2] at parameter 1 group.
- Because EU- I and EU-2 operate separately, both EU- I and EU-2 can be used as a high or low 2nd alarm operation.
- When selecting ∠ЬЯ or 5ЬЯ function in EU- 1, EU-2 of parameter 2 group, alarm cannot be operated.

Alarm operation

Mode	Name	Alarm operation	Description
AL - D	_		No alarm output
AL-I	Deviation high-limit alarm	OFF H ON SV PV 100°C 110°C High deviation: Set as 10°C	If deviation between PV and SV as high- limit is higher than set value of deviation temperature, the alarm output will be ON.
AL-2	Deviation low-limit alarm	ON H OFF PV SV 90°C 100°C Low deviation: Set as 10°C	If deviation between PV and SV as low- limit is higher than set value of deviation temperature, the alarm output will be ON.
AL-3	Deviation high/low-limit alarm	ON THU OFF UH TON ON THU OFF UH TON ON THU OFF UH TON ON THU ON ON ON THU ON ON ON ON ON ON ON ON ON ON	If deviation between PV and SV as high/low-limit is higher than set value of deviation temperature, the alarm output will be ON.
AL-4	Deviation high/low-limit reserve alarm	OFF ↓H ↑ ON ↑H ↓ OFF PV SV PV 90°C 100°C 110°C High/Low deviation: Set as 10°C	If deviation between PV and SV as high/low-limit is higher than set value of deviation temperature, the alarm output will be OFF.
AL-5	Absolute value high limit alarm	OFF HON ON OFF HON ON OFF HON ON OFF HON ON ON OFF HON ON ON ON ON ON ON ON ON ON	If PV is higher than the absolute value, the output will be ON.
AL-6	Absolute value low limit alarm	ON THU OFF ON THU OFF ON THU OFF SV PV 90°C 100°C Absolute-value Alarm: Set as 90°C Set as 110°C Absolute-value Alarm: Set as 110°C	If PV is lower than the absolute value, the output will be ON.
5 b R.□	Sensor break Alarm	_	It will be ON when it detects sensor disconnection.
L Ь Я.□	Loop break Alarm	_	It will be ON when it detects loop break.

imes H: Alarm output hysteresis [ЯНЧ5]

Alarm option

Mode	Name	Description	
AL-A	Standard alarm	If it is an alarm condition, alarm output is ON. If it is a clear alarm condition, alarm output is OFF.	
AL-b	Alarm latch	If it is an alarm condition, alarm output is ON and maintains ON status.	
AL-C	Standby sequence	First alarm condition is ignored and from second alarm condition, standard alarm operates. When power is supplied and it is an alarm condition, this first alarm condition is ignored and from the second alarm condition, standard alarm operates.	
AL-d	Alarm latch and standby sequence	If it is an alarm condition, it operates both alarm latch and standby sequence. When power is supplied and it is an alarm condition, this first alarm condition is ignored and from the second alarm condition, alarm latch operates.	

(A) Photo electric sensor

(B) Fiber optic sensor

(C) Door/Area sensor

(D) Proximity sensor

(E) Pressure sensor

(F) Rotary

(G) Connector/

(H) Temp. controller

(I) SSR/ Power controller

(J) Counter

ner

Panel neter

(M) Tacho/ Speed/ Pulse meter

(N) Display unit

(P)

(P) Switching mode power supply

(Q) Stepper motor& Driver&Controlle

(R) Graphic/ Logic panel

(S) Field network device


> T) Software


(U) Other

Functions

PID auto tuning function automatically measures the thermal characteristics and response of the control system and then executes its value under high response & stability after calculating the time constant of PID required to control optimum temperature.

- Execute the auto tuning function at initial time after connecting the controller & the sensor.
- Execution of auto tuning is started when pressing AT key for 3 sec. or more.
- When the auto tuning is started, AT indicator will flash, and when the indicator is OFF, this operation will stop.
- While the auto tuning function is executing, it is stopped by pressing AT key for 5sec. or more.
- When the power turns off or the stop signal is applied while auto tuning function is executing, time constant of PID is not changed and it remembers the value before power turns off.
- Time constant of PID selected by auto tuning function can be changed in parameter 1 group.
- It has two kinds of auto tuning mode auto tuning operation is executed at setting value(SV) in £ ☐ 1 mode which is factory default. Auto tuning operation in £ ☐ 2 mode is executed in 70% of setting value(SV). Mode change is available in REE of the parameter 2 group.





 Execute the auto tuning function again periodically, because the thermal characteristics for the control object can be changed when the controller is used continuously for a long time.

○ Sub output [*E U* - 1, *E U* - 2]

Sub output can execute as main control output and sub function as well. There is one sub output in this unit.

- This sub output is relay "1a" contact output.
- 1 mode can be selected among 7 kinds of alarm mode or LBA operated when the heater line is cut, SBA operated when the sensor line is cut.
- The Sub output can be latched ON or automatically reset depending on the alarm option mode selected.
- When the sensor line or the heater line is cut, SBA or LBA output turns on. This "Output on" status must be reset by turning the power off.

Sensor Break Alarm [56月]

This function causes the sub output to turn on when the sensor line is cut or open. It is easier to check that whether the sensor line is cut or not through buzzer or etc by exterior sub output(relay contact).

 For using SBA function, set 5bA at EU- I or EU-2 in parameter 2 group and SBA output operates as EV1 OUT or EV2 OUT contact.

© Loop Break Alarm [L Ь Я]

LBA function is to diagnose an abnormal temperature of the control system. If the temperature of the control system is not changed within ±2°C during setting time of LBA, the LBA output will be ON.

- Ex) When setting value(SV) is 300°C, process value(PV) is 50°C, this unit controls 100%. In this time if there is no change of system temperature, it recognizes Heater is cut off then LBA output will be ON.
- LBA output can be selected at EV1 of the parameter 2 group.
- If L bA output is not selected at event output, it will not be displayed in parameter 1 group.
- Set range of LBA: 1 to 999 sec.
- If thermal response of the control system is slow, LBA value should be set to a high value.
- LBA output operates when the manipulated value of the controller is 0% and 100%. In case the LBA output is ON, please check the following;
 - 1) Short-circuit or cutting of the temp. sensor.
 - ② Abnormal condition of the equipment (magnet, sub-relay, etc.)
 - 3 Abnormal condition of the load(heater, cooler)
 - Wrong-wiring or cutting of the other cables.
- Once SBA is ON due to broken sensor, it will not reset, although sensor is connected. In this case, turn off the power then turn on again.

If error is occurred while the controller is operating, it will be displayed as follow.

- LLLL is flashing when measured input temperature is lower than input range of the sensor.
- HHHH is flashing when measured input temperature is higher than input range of the sensor.
- aPEn is flashing when the input sensor is not connected or its wire is cut.

H-82 Autonics

◎ ON/OFF control


ON/OFF control is called two position control because the output turns on when PV falls lower than SV and the output turns off when PV is higher than SV.

This control method is not only for controlling temperature, but also it is basic control method for sequence control.

- If you set value P as Q.D in parameter 1 group, ON/OFF control will operate.
- There is a programmable temperature difference between ON and OFF in ON/OFF control, if difference is too small, then hunting(chattering) can occur.
- Temperature difference can be set in Hy5 mode of parameter 1 group. Setting range is 1 to 100(or 0.1 to 100.0).
- H45 mode is displayed when P value is 0.0, but H45 will not be displayed, and then jump if P value is not 0.0.
- This ON/OFF control should not be applied when equipment(cooling compressor) to be controlled can be damaged by frequent ON and OFF.
- Even if ON/OFF control is stable status, the hunting can be occurred by setting value in Hy5 or capacity of the heater or response characteristic of the equipment to be controlled or installing position of the sensor. Please consider above points to minimize the hunting when designing the system.

Proportional control has deviation because rising time is not same as falling time, even if the unit operates normally. Manual reset function is used at proportional control mode only.

- If set r E 5 t function in parameter 1 group, the manual reset will run.
- When PV and SV is equal, <code>rE5E</code> value is 50.0% and when control is stable, if the temperature is lower than SV, <code>rE5E</code> value should be higher and on the other hand, <code>rE5E</code> value should be smaller.
- rE5E setting method according to result of control.



□ Decimal point setting [dot]

Decimal point is displayed as dat in parameter 2 group when the input is analog only.(0-10VDC, 1-5VDC, DC4-20mA)


O Dual PID control

When controlling temperature, two types of control characteristic are available as below.

One is when you need to minimize the time which PV reaches to SV as like(Fig. 1). The other is when you need to minimize overshoot even though the reaching time(PV to SV) is slow(Fig. 2).


- There are high-speed response type and low-speed response type built in this unit. Therefore user can select each function according to their application.
- You can select dual PID control function in parameter 2 group. It is selectable PI dF or PI d5 in PI dE mode.
- P! d.F (high-speed response type)

This mode is applied to machines or systems which require high-speed response.



● P1 d.5 (low-speed response type)

It is PID Slow, used to minimize overshoot even though the response is slow. For control temperature of oil, plating machine have a possibility of fire with overshoot, PI d.5 (limit over) should be used.



*Factory default setting is P1 d.5.

Please select mode according to control system.

RS485 communication

It is used on the purpose that transmitting PV to an external equipment, setting SV at the external equipment.

- It can be set at 6P5, Adr 5 in second parameter 2 group.
- Communication speed[bP5] set range: 2400, 4800, 9600bps
- Start bit(1bit, fixed), Stop bit(1bit, fixed), Parity bit(none)
- Communication address[Rd 5] set range: 1 to 99
- Communication converters(sold separately)
 - SCM-38I(RS-232C to RS485 converter)
 - SCM-US48I(USB to RS485 converter)
 - SCM-WF48(Wi-Fi to RS485/USB communication converter(available soon)

(A) Photo electric sensor

(B) Fiber optic sensor

> (C) Door/Area sensor

(D) Proximity sensor (E) Pressure

sensor

(F) Rotary encoder

(G) Connector/ Socket

(H) Temp. controller

(I) SSR/ Power controller

Counter

K) imer

Panel meter

(M) Tacho/ Speed/ Pulse meter

(N) Display unit

(P) Switching

mode power supply

(Q)
Stepper

Driver&Controll
(R)

(R) Graphic/ Logic panel

Field network device

I) Software

(U) Other

○ Cool / Heat function [□ - F +]

Generally there are two ways to control temperature, one(heat-function) is to heat when PV is getting down(heater). The other(cool-function) is to cool when PV is getting higher(freezer).


These functions are operating oppositely when it is ON/ OFF control or proportional control. But in this case PID time constant will be different due to PID time constant will be decided according to control system when it is PID control

- Cool-function and heat-function can be set at Parameter 2 group.
- Cool-function [LaaL] and heat-function [HERL] must be set correctly according to the application, if set as opposite function, it may cause a fire.(If set cool-function [LaaL] at heater, it will be maintained ON and it may cause a fire.)
- Avoid changing heat-function to cool-function or coolfunction to heat-function when the unit is operating.
- It is impossible to operate both function at once in this unit. Therefore, only one function should be selected only.
- Factory default setting is heat-function [HERL].

SV2 function [5*U*−2]

If using SV2 function, it changes the temperature of control system to the second setting value by external relay contact signal.

It can change the setting value as sequentially by relay contact without key operation.



- It can set SV2 at required time and particular area as like the above chart.
- SV2 is in parameter 1 group.
- · Application:


The control system, which has to maintain constant temperature such as oven. If you open the door, temperature will go down.

In this case, if you set the second setting value higher than setting value, temperature will rise fast. Therefore, after installing a micro-switch in order to detect the door Open/Close and connect it to SV2(the second setting value should be higher than SV) then it controls temperature of oven efficiently.

Ramp function is to delay the rising time or falling time of temperature. If you change setting value at stable state of control, it forces to rise or fall the temperature of control system during setting time at $rR\bar{n}P$, rRPd in parameter 1 group.

- Set คลิค is ON in parameter 2 group for using ramp function
- Set the rising time and falling time at RPU mode and RPU mode of parameter 1 group.
- Ramp function will be operating when changing the set value at stable control status or supply the power again after the power was removed.
- The setting range of rising and falling time is 1 to 99 minute.


■ Ramp rising[- APU](delay of rising time)



It makes delay rising temperature when change the set value at stable control status or delay the initial rising temperature as like above picture.

※ ¬ RPU time cannot be shorter than rising time(tu) of temperature when Ramp function is not used.

■ Ramp falling[- RPd](delay of falling time)



It controls falling temperature as like above.


※ r RPd time cannot be shorter than falling time(td) of temperature when Ramp function is not used.

H-84 Autonics


Input correction is to correct deviation occurred from temperature sensor such as thermocouples, RTD, Analog sensor etc. If you check the deviation of every temperature sensor precisely, it can measure temperature accurately.

- Input revise can be set at I n-b mode in parameter 1 group.
- Use this mode after measuring deviation occurred from temperature sensor exactly. Because if measured deviation value is not corrected, dis-played temperature may be too high or too low.
- Set range: -49 to 50°C(-50.0 to 50.0°C)
- When you set the Input revise value, you may need to record it, because it will be useful when performing maintenance

 In case of measuring or controlling humidity & pressure, flux, etc, it uses the proper converter which is converting the measuring value to DC4-20mA or 1-5VDC or 0-10VDC.




- To use analog output of converter as controller input, select the input type as same as analog output conditions.(This should be operated in power-off status.)
- This unit has the mode for the converter built-in.
- Please select R - ! (0-10VDC) or R - 2 (1-5VDC) or R - 3 (DC4-20mA) in selection mode of input in parameter 2 group.
- Set the input value by High scale[H-5E] and Low scale [L-5E] mode.
- Please connect the analog output of the converte to the temperature sensor terminal of the controller. Please be cautious of the polarity.
- After the procedure, it is controlled same with temperature control.
- Example of usage



Output connections


For more information about output, refer to the H-139 page.

Application of relay output type




Keep power relay as far away as possible from TZ/TZN Series. If wires length of **A** is short, electromotive force occurred from a coil of magnet switch & power relay may flow in power line of the unit, it may cause malfunction. If wires length of **A** is short, please connect a mylar condenser 104(630V) across coil of the power relay "" to protect electromotive force.

Application of SSR drive output type



- ※Please use a cooling plate or it may cause the capability deterioration, breakdown of SSR for a long usage.


Application of current output(DC4-20mA)




XIt is important to select SCR unit after checking the capacity of the load.

XIf the capacity is exceeded, it may cause a fire.

Application of transmission output(DC4-20mA)



Application of communication output(RS485)



(A) Photo electric sensor

(B) Fiber optic sensor

(C) Door/Area sensor

(D) Proximity sensor

(E) Pressure sensor

(F) Rotary encoder

(G) Connector/ Socket

(H) Temp. controller

> (I) SSR/ Power controller

Counter

(K) Timer

(M) Tacho/ Speed/ Pulse meter

(N) Display unit

O) Sensor controller

(P) Switching mode power supply

Stepper motor& Driver&Controller

(R) Graphic/ Logic panel

(S) Field network device

> (T) Software


(U) Other

Communication output

O Interface

Standard	EIA RS485
Number of connections	Max. 31units. It is available to set address 01 to 99.
Communication method	2 wire half duplex
Synchronous method	Asynchronous type
Communication distance	Within 1.2km
Communication speed	2400, 4800, 9600(available to set)
Start bit	1bit(Fixed)
Stop bit	1bit(Fixed)
Parity bit	None
Data bit	8bit(Fixed)
Protocol	BCC


System ordering



XUse a proper twist pair for communication.


© Communication control ordering

- 1. The communication control ordering of TZ/TZN Series is exclusive protocol.
- 2. After 4sec. being supplied the power into master system. then able to start communicating.
- 3. Initial communication will be started by master system. When Command signal comes out from master system then TZ/TZN Series will respond.



Communication Command and Block

Format of Command and Response



① Start code It indicates the first of Block STX \rightarrow [02H], in case of response, ACK will be added.

This code is master system can discern TZ/TZN Series and able to set within range of 01 to 99.(BCD ASCII)

③ Header code:

It indicates command as 2 alphabets as below. RX(Read request) → R[52H], X[58H] RD(Read response) → R[52H], D[44H] WX(Write request) → W[57H], R[58H] WD(Write response) → W[57H], D[44H]

- ④ Text: It indicates the detail contents of Command/ Response.(see command)
- ⑤ END code: It indicates the end of Block. ETX → [03H]
- BCC: It indicates XOR operating value from the first to ETX of the protocol as abbreviation of TZ/TZN.

© Communication Command

• Read [RX] of measurement/setting value: Address 01, Command RX

1.Command(Master)

① Command

STX	0	1	R	Х	Р	0	ETX	FSC
Start	Add	ress	Comi he		P:Proce S:Settin	ss value ig value	End	всс

② Application: Address(01), Header code(RX), Process value(P)

		1 100	COO VU	iuc(i)				
STX	0	1	R	Х	Р	0	ETX	FSC
02	30	31	52	58	50	30	03	BCC

Write [WX] of setting value: Address 01, Command WX

1.Command(Master)

Command

STX	0	1	W	Χ	S	0	Symbol	10 ³	10 ²	10¹	10°	ETX	FSC
Start	Add	ress	Comr	mand S:Setting			Space/-	10 ³	10 ²	10¹	10°	End	всс

② Application: In case of writing Address(01), Heading Coad(WX), Setting value(S) +123.

							Symbol						
02	30	31	57	58	53	30	20	30	31	32	33	03	всс

Response

• Read of process/Setting value

1. In case of receiving normal process value: The data is transmitted adding ACK[60H]. (In case process value is +123.4)

A C K	S T X	0	1	R	D	Р	0	Symbol	10³	10²	10¹	10°	Decimal point	E T X	F S C	N U L L
A C K	S T X	0	1	R	D	Р	0	Space	1	2	3	4	1	E T X	ВСС	N U L L
06	02	30	31	52	44	50	30	20	31	32	33	34	31	03	ВСС	00

2. In case process value is -100

			•													
A C K	S T X	0	1	R	D	Р	0	_	0	1	0	0	0	E T X	B C C	ZULL
06	02	30	31	52	44	50	30	2D	30	31	30	30	30	03	B C C	00

XIt is responded with 1 byte sized NULL(00H) at the end of response frame(next BCC 16).

• Write of setting value

In case setting value is -100

A C K	S T X	0	1	W	D	S	0	Symbol	10 ³	10 ²	10¹	10°	E T X	F S C
A C K	S T X	0	1	W	D	s	0	_	0	1	0	0	E T X	B C C
06	02	30	31	57	44	53	30	2D	30	31	30	30	03	B C C

Others: In case of no response of ACK

- ① When the address is not the same after receiving STX.
- ② When receiving buffer overflow is occurred.
- ③ When the baud rate or others communication setting value are not the same.
- When there are no ACK response
- ① Check the status of lines
- ② Check the communication condition(Setting value)
- ③ When assuming the problem is due to noise, try to operate communication 3 times more until recovery.
- When occurred communication failure frequently, please adjust the communicating speed.

Proper usage

O Simple "error" diagnosis

• When the load(Heater etc) is not operated

Please check operation of the OUT indicator located in front panel of the unit.

If the OUT indicator does not operate, please check the parameter of all programmed mode.

If indicator is operating, please check the output(Relay, SSR drive, DC4-20mA current) after separating output line from the unit.

But, the out indicator is not operated for DC4-20mA

• When it displays oPEn during operation

This is a warning that external sensor is open. Please turn off the power and check the wire state of the sensor. If sensor is not open disconnect sensor line from the unit and short the input +, - terminal. Turn on the power of the unit and check the controller displays room temperature.

If this unit cannot display room temperature, this unit is broken. Please remove this unit and contact our service center.(When the input mode is thermocouple, it is available to display room temperature.)

In case of indicating Err () in display

This Error message is indicated in case of damaging inner chip program data by outer strong noise.

In this case, please send the unit to our after service center after removing the unit from system.

Noise protection is designed in this unit, but it does not stand up strong noise continuously. If bigger noise than specified(Max. 2kV) flows in the unit, it can be damaged.

© Caution for using

- Please use the terminal(M3.5, Max. 7.2mm) when connecting the AC power source.
- Please use separated line from high voltage line or power line in order to avoid inductive noise.
- Please install power switch or circuit-breaker in order to cut power supply off.
- The switch or circuit-breaker should be installed near by users
- This unit is designed for temperature controlling only. Do not apply this unit as a voltage meter or a current meter.
- Be sure to use compensating wire when extending wire from controller to thermocouple, otherwise a temperature deviation will occur at the point where wires are connected to each other.
- In case of using RTD sensor, 3-wire type must be used.
 If you need to extend the line, 3-wires must be used with the same thickness as the line. It might cause temperature difference if the resistance of line is different.
- In case of making power line and input signal line close, line filter for noise protection should be installed at power line and input signal line should be shielded.
- Keep away from the high frequency instruments.(High frequency welding machine & sewing machine, big capacitive SCR controller)
- If you want to change the input sensor, reset switches(SW1, SW2) according to each input specification after power off. Turn on power and then set sensor mode by front keys at second flow chart.
- This SSR drive output and current output of this controller are insulate from internal power.
- Do not connect power line to sensor connecting part. The inner circuit may be damaged.
- Installation environment
 - · It shall be used indoor.
 - Altitude Max. 2000m.
 - Pollution Degree 2
 - Installation Category II.

(A) Photo electric sensor

(B) Fiber optic sensor

(C) Door/Area sensor

(D) Proximity sensor (E) Pressure

(F)

C)

Connector/ Socket

(H) Temp. controller

(I) SSR/ Power controller

> J) Counter

mer

(M) Tacho/ Speed/ Pulse meter

N) Display

O) Sensor controller

(P) Switching mode power supply

(Q) Stepper motor& Driver&Controlle

Graphic/ Logic panel

(S) Field network device

> T) oftware

(U) Other