DRW200035AC Autonics

Color LCD Graphic Panel



GP-A Series

For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

The specifications, dimensions, etc. are subject to change without notice for product improvement. Some models may be discontinued without notice.

Features

- Equipped with TFT LCD for realizing True color
- Horizontal/Vertical installation according to environment
- $\bullet \ \text{Available to monitor device of the connected controllers even without user screen data}\\$
- Using user screen drawing program 'atDesigner'
- : More variety functions, objects and library image $\,$
- : Intuitive user interface
- : Multilingual table function: switching language of user screen by touching a button
- Various communication interface: RS232C, RS422, Ethernet, CAN

Safety Considerations

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- ▲ symbol indicates caution due to special circumstances in which hazards may occur.

▲ Warning Failure to follow instructions may result in serious injury or death.

01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.)

Failure to follow this instruction may result in personal injury, economic loss or fire.

 Do not use the unit in the place where flammable/explosive/corrosive gas, high humidity, direct sunlight, radiant heat, vibration, impact, or salinity may be present.

Failure to follow this instruction may result in explosion or fire.

03. Use the unit within the rated specifications.

Failure to follow this instruction may result in fire or shortening the life cycle of the product.

04. Do not connect, repair, or inspect the unit while connected to a power source. Failure to follow this instruction may result in fire.

05. Check 'Power Wiring' and 'Serial Interface' before wiring.

Failure to follow this instruction may result in fire.

06. In preparation for product damage, communication error, or malfunction, install external limit switch, emergency stop switch, or other protection circuit.

Failure to follow this instruction may result in personal injury, economic loss or fire

07. Since Lithium battery is embedded in the product, do not disassemble or burn the unit.

Failure to follow this instruction may result in fire.

08. Do not disassemble or modify the unit.

Failure to follow this instruction may result in fire.

09. Please contact to us for battery replacement.Using an unauthentic battery may result in fire or product damage.

Failure to follow this instruction may result in electric shock or fire.

⚠ Caution Failure to follow instructions may result in injury or product damage.

01. Use dry cloth to clean the unit, and do not use water or organic solvent.

02. When connecting the power input, use AWG 23 cable or over and tighten the terminal screw with a tightening torque of 0.5 to 0.8N·m.

Failure to follow this instruction may result in fire or malfunction due to contact failure.

 Keep the product away from metal chip, dust, and wire residue which flow into the unit.

Failure to follow this instruction may result in fire or product damage.

04. Do not touch the front LCD screen over 2 points at the same time.

 $\label{eq:Failure} \textit{Failure to follow this instruction may result in malfunction}.$

05. Do not put any heavy object on the front screen.
Failure to follow this instruction may result in malfunction due to deformation of LCD and touch panel.

Cautions during Use

- Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected accidents.
- 24VDC == power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Install a power switch or circuit breaker in the easily accessible place for supplying or disconnecting the power.
- $\bullet \ \, \text{Operate the product after supplying power to the product, input/output equipment, and} \\$ load. If operate product before supplying power, it may result in output error or malfunction.
- · Keep away from high voltage lines or power lines to prevent inductive noise. Do not use near the equipment which generates strong magnetic force or high frequency noise.
- Make a required space around the unit for radiation of heat, and do not block ventilation
- Do not push the touch panel with a hard and sharp object or push the panel with excessive force. It may result in fire or malfunction.
- $\bullet \ \ \text{When skin is smeared with liquid crystal from the broken LCD, rinse with running water for }$ over 15 minutes. If it gets into the eyes, rinse eyes with running water for over 15 minutes and
- · This unit may be used in the following environments.
- Indoors (in the environment condition rated in 'Specifications')
- Altitude max. 2,000m
- Pollution degree 2
- Installation category II

Cautions during Wiring

- For power supply, use the wire of which cross section is at least 0.75mm² and use the wire of which cross section is at least 1.25mm2 for grounding.
- Use ring crimp terminal with at least 3mm of internal diameter and less than 6mm of external diameter.
- Do not apply power before power line connection.
- Check power polarity.
- Tighten the terminal screw with 0.5 to 0.6N.m torque.
- Ground resistance should be less than $100\,\Omega$ and ground it separately.

Product Components

- Graphic panel + built in batterv
- 4.6 / 5.7 / 7.0 inch: 4 fixing brackets
- 10.4 inch: 6 fixing brackets, CAN connector
- Sold separately: communication cable

Manual

For the detailed information and instructions, please refer to the manuals, and be sure to follow cautions written in the technical descriptions.

Visit Autonics web site to download manuals.

· GP-A Series user manual

It describes general information about installation and system of GP-A Series.

· atDesigner user manual

It describes how to design user screen and how to use HMI function.

· GP/LP user manual for communication

It describes how to connect with external devices such as PLC.

Ordering Information

This is only for reference.

For selecting the specific model, follow the Autonics web site.



Screen size

046: 4.6 inch 057: 5.7 inch 070: 7.0 inch

104: 10.4 inch

Display color

8: 262.144 color 9: 16,777,216 color

Interface

Model	€	RS232C	RS422	CAN	Micro SD	USB Host	USB Device	Ethernet
GP-A	6	1	1	-	-			
046/057/070	7	2	-	-	-	1	,	1
CD 4104	8	1	1	1	1	1	1	1
GP-A104	9	2	-	1	1			

Specifications

	GP-A046	GP-A057	GP-A070	GP-A104				
Screen size	4.6 inch	5.7 inch	7.0 inch	10.4 inch				
LCD type	TFT Color LCD							
Resolution	800×320 pixel	640×480 pixel	800×480 pixel	800×600 pixel				
Display area	108×43.2 mm	115.2×86.4 mm	154.4×93.44 mm	211.2×158.4 mm				
Display color	16,777,216 color	262,144 color	16,777,216 color	16,777,216 color				
LCD view angle (top/bottom/left/right)	Within 75°/70° /80°/80° of each	Within 70°/70° /80°/80° of each	Within 50°/60° /65°/65° of each	Within 60°/70° /80°/70° of each				
Backlight	White LED	White LED						
Luminance adjustment	Adjustable by software							
Touch	Resistive type (4-wire)							
Approval	C€ №							
Unit weight (packaged weight)	≈ 272 g (≈ 382 g)	≈ 489 g (≈ 644 g)	≈ 520 g (≈ 706 g)	≈ 1.07 kg (≈ 1.62 kg)				
Serial interface	RS232C, RS422							
USB interface	USB Host, USB Device(USB2.0)							
Ethernet interface	IEEE802.3(U), 10/100Base-T							
CAN interface	24V CAN transceiver							
External storage	Micro SD up to 32GB (FAT16/32)							
Real-time controller	RTC embedded							

3 years at 25°C

Supportive interface can be diffe	rent up to model. For the detailed information, please refer to 'Ordering Information'.
Language	Korean, English
Text	Bitmap and vector font
Memory for user screen	64MB
Number of user screen	100 pages
Power supply	24 VDC==
Allowable voltage range	90 to 110% of power supply
Power consumption	4.6 inch: ≤ 4.8 W, 5.7 / 7.0 inch: ≤ 7.2 W, 10.4 inch: ≤ 8.0 W
Insulated resistance	≥ 100 MΩ (500 VDC== megger) (between all terminals and case)
Ground	3rd grounding (≤ 100 Ω)
Noise immunity	The square wave noise (pulse width: 1µs) by the noise simulator ± 0.5 kV
Dielectric strength	500 VAC~ 50/60 Hz for 1 minute (between all terminals and case)
Vibration	0.75 double amplitude at frequency of 10 to 55 Hz in each X, Y, Z direction for 1 hour
Vibration (malfunction)	0.5 double amplitude at frequency of 10 to 55 Hz in each X, Y, Z direction for 10 minutes
Shock	147 m/s² (approx. 15 G) in each X, Y, Z direction for 3 times
Shock (malfunction)	100 m/s² (approx. 10 G) in each X, Y, Z direction for 3 times
Ambient temperature	0 to 50°C, storage: -20 to 60°C (a non freezing or condensation environment)
Ambient humidity	35 to 85%RH, storage: 35 to 85%RH (a non freezing or condensation environment)
Protection structure	IP65 (front panel, IEC standard)

Interface

Battery life cycle

Interface is different up to the model.

For the detailed information about each interface, refer to the GP-A Series user manual and GP/LP user manual for communication

■ Serial port (RS232C/RS422)

S232C		RS422				
Port	Pin	function	Port		Pin function	
	1	N/A	_	1	TXD+	
5	2	RXD		2	RXD+	
4 • 9	3	TXD	2 0 6	3	N/A	
3 • 8	4	DTR	3 0 7	4	N/A	
1 • 17	5	SG	1 01 8	5	SG	
2 6	6	DSR	4 0 9	6	TXD-	
	7	N/A	5 (e) 3	7	RXD-	
_	8	N/A	1	8	N/A	
D-sub 9 Pin Male	9	N/A	D-sub 9 Pin Female	9	N/A	

■ USB port

_ 000 poi.t			
Туре	Port Function		
USB Host		Coping data between storage and GP Firmware upgrade Connecting external device (bar-code reader, printer, etc.) External memory: max. 32GB (supported file system: FAT16, FAT32)	
USB Device		atDesigner project upload/download	

■ Ethernet port

It is available to upload/download project file by connecting PC and atDesigner, and monitor PLC which supports Ethernet communication protocol.

CAN port


	•		
Number	Color	Function	Configuration
1	Black	24VDC==(-)	
2	Blue	CAN_L	CAN L
3	None	SHIELD) // ← SHIELD (•
4	White	CAN_H	
5	Red	24VDC=(+)	→ □ V+ .

■ Micro SD

External memory: max. 32GB (supported file system: FAT16, FAT32)


Dimensions

• Unit: mm, For the detailed dimensions of the product, follow the Autonics web site.




	Α	В	С	D	E	F
4.6 inch	135	143.5	75.5	6.5	36	67
5.7 inch	160	168.5	128.5	6.5	36	120
7.0 inch	185	194	134	6.5	28.5	125
10.4 inch	260	273	212	7.2	34	200

• Panel cut-out




	Α	В	С
4.6 inch	135.5°1.1	67.5 ^{+1.1}	≤ 4-R3
5.7 inch	160.5 ^{*1.0}	120.5*1.0	≤ 4-R3
7.0 inch	186°1.1	126 0	≤ 4-R3
10.4 inch	260.5°1.1	200.5 0	≤ 4-R3

• Fixing bracket



Installation

- Set the product in panel. (panel thickness: ≤ 4mm)
 When installing GP-A104 on panel, make 100mm of space from upper, lower, right, left side of the product on the panel and back side of panel. It is for preventing effect of electromagnetic waves and heat from other controllers. [Image 1]
- 2. Set fixing brackets in the fixing bracket mounting slots. [Image 2] $\,$
- 3. Tighten the fixing bracket with M4 Screw driver and tightening torque is 0.5 to 0.6N \cdot m.



Software

Visit Autonics web site to download software.

• atDesigner

at Designer is for editing project file.

 $\label{lem:commended} Recommended computer specification for at Designer is as below.$

Item	Recommended spec	
Operating system	Nindows 7/10	
CPU	Intel Core i5-2nd gen. 2500	
Memory	8GB	
Hard disk	8GB free space	
Resolution	1920×1080	

• Firmware

Please refer to 'GP-A Series user manual' for firmware upgrade.