
# **Monitoring Technique**

# VARIMETER **Motor Load Monitor BA 9067**







### **Function Diagram**



### **Circuit Diagrams**





BA 9067.38/001



- According to IEC/EN 60 255, DIN VDE 0435-303
- Detection of •
- underload
- overload
- · Measures effective power
- 1 changeover contact for underload, 1 changeover contact for overload
- Adjustable start-up delay t
- Adjustable operate delay
- Open or closed circuit operation
- Without neutral
- Optionally with neutral
- Width 45 mm

#### Approvals and Marking



#### Applications

The BA 9067 is used to monitor variable loads on industrial motors

#### Function

The BA 9067 monitors the effective power consumption  $p = U x I x \cos \varphi$  of electrical consumers. With 2 potentiometers the underload and the overload value can be set. Under- and overload is indicated by 2 yellow LEDs as long as the motor is running on under- or overload. When the motor is switched of the LEDs turn off because the BA 9067 is also disconnected. After an operate delay an output relay is activated. In addition the unit includes a start-up delay and a green LED to show operational state. The BA 9067.38 is for single phase or 3 phase 4 wire systems and the BA 9067.38/001 for 3 phase 4 wire systems.

On DIP switches settable:

- Input current range up to 1, 2, 3, 4, 5 A or up to 2, 4, 6, 8, 10 A
- closed or open circuit operation

#### Connection

The connection has to be made according to the connection diagrams. To feed in the motor current the terminals i and k have to be used keeping in mind the direction of the current. The terminal i is wired to the supply side and the terminal k to the motor side. The max. current over these terminals is 5 resp. 10 A. For higher values a current transformer must be used.

#### **Connection Details**

If the measurement is still incorrect the connections i and k must be exchanged against each other.

### **Technical Data**

# Input

 Nominal voltage U<sub>N</sub>, L1/N:
 AC 230, 400 V

 BA 9067.38:
 AC 230, 400 V

 Nominal voltage U<sub>N</sub>, L1/L2/L3:
 BA 9067.38/001:

 BA 9067.38/001:
 3 AC 230, 400, 690 V

 Application class: II
 Voltage range: 0.8 ... 1.05 U<sub>N</sub>

 Voltage range:
 0.8 ... 1.1 U<sub>N</sub>

50 / 60 Hz

16 A, 3 s

0.1 ... 1 s

0.3 ... 3 s

≤ 50 ms

4 A gL

3 A / AC 230 V

1 A / AC 230 V

2 x 10<sup>5</sup> switching cycles

1800 switching cycles / h

30 x 10<sup>6</sup> switching cycles

5 A

1 ... 5 A (Terminals i-k), or 2 ... 10 A

1 ... 10 s

1 ... 30 s

IEC/EN 60 947-5-1

IEC/EN 60 947-5-1

IEC/EN 60 947-5-1

IEC/EN 60 947-5-1

1 ... 10 on relative scale 1 ... 10 on relative scale

1 changeover contact for  $P_1$ 1 changeover contact for  $P_2$ 

± 3 % of max. value

2 VA

Frequency range of U<sub>N</sub>: Nominal consumption: Nominal current: Max. overload:

# Setting Ranges

P1: P2: Setting accuracy: Operate delay t<sub>v</sub>: Start-up delay t<sub>v</sub>:

Output

Contacts BA 9067.38:

Release delay: Thermal current  $I_{th}$ : Switching capacity to AC 15 NO contact: NC contact: Electrical life: to AC 15 at 3 A, AC 230 V: Permissible switching frequency: Short circuit strength max. fuse rating: Mechanical life:

### General Data

Operating mode: Temperature range: Clearance and creepage distances	Continuous operation - 20 + 60 °C	n
rated impuls voltage / pollution degree: EMC	4 kV / 2	IEC 60 664-1
Electrostatic discharge: HF irradiation: Fast transients: Surge voltages between	8 kV (air) 10 V / m 2 kV	IEC/EN 61 000-4-2 IEC/EN 61 000-4-3 IEC/EN 61 000-4-4
wires for power supply: between wire and ground: HF-wire guided: Interference suppression:	1 kV 2 kV 10 V Limit value class B	IEC/EN 61 000-4-5 IEC/EN 61 000-4-5 IEC/EN 61 000-4-6 EN 55 011
Degree of protection Housing:	IP 40	IEC/EN 60 529
Terminals:	IP 20	IEC/EN 60 529
Housing:	Thermoplastic with V0 behaviour according to UL subject 94	
Vibration resistance:	Amplitude 0.35 mm frequency 10 55 Hz IEC/EN 60 068-2-6	
Climate resistance:	20 / 060 / 04	IEC/EN 60 068-1
Terminal designation:	2 x 2.5 mm <sup>2</sup> solid or	
	2 x 1.5 mm <sup>2</sup> stranded wire with sleeve DIN 46 228/-1/-2/-3/-4	
Wire fixing:	Flat terminals with self-lifting	
Mounting: Weight:	clamping piece DIN rail 360 g	IEC/EN 60 999-1 IEC/EN 60 715

#### Dimensions

Width x height x depth:

45 x 74 x 131 mm


Standard Type

BA 9067.38/001 3 AC 400 V Article number: • Without neutral	
Output:	1 changeover contact for underload,
	1 changeover contact for overload
<ul> <li>Operate delay t<sub>v</sub>:</li> </ul>	10 s
<ul> <li>Start-up delay t<sub>a</sub>:</li> </ul>	30 s
<ul> <li>Nominal voltage U<sub>N</sub>:</li> </ul>	3 AC 400 V
Nominal current:	5 A
Width:	45 mm


# Variants

BA 9067.38:	with neutral
	3 AC 230, 400 V
BA 9067.38/020:	detects overload on 2 independent
	seetable overload values, open circuit
	operation
BA 9067.38/030:	same as BA 9067.38/020, but closed
	circuit operation


### Ordering example for variants



#### **Connection Examples**



#### Set-up Procedure






The required measuring range must be selected by putting the relevant DIP-switch to left position. All othe range selector DIP-switches are in right position.

Before setting up the unit we recommend to evaluate the current expected to flow in order to preset the current range with the DIP-switches.

Example: Motor 55 kW Nominal current 100 A Current transformer to be used 100/5 DIP-switch to be set to position 5 A



### Variant 1:

This method is recommended when the different load situations of the motor cannot be achieved during set-up.

- 1.) Calibration of the device according to the following equation:  $P_{max}=~\sqrt{3}$  x U\_{N} x I x ü
  - P<sub>max</sub> = effective power measured by the device at max. scale value (pot in pos. 10)
  - $U_N = Nominal voltage of the three phase system (e.g. 400 V)$
  - I = current selected on DIP-switches (e.g. 5 A)
  - $\ddot{u}$  = transformation ratio of CT, if connected (e.g. 100/5 = 20)

Result: P<sub>max</sub> = 69.3 kW

2.) Evaluate the efficiency factor of the motor at the required load situations from tables.

e.g.  $\eta \approx 0.9 \dots 0.93$  depending on load for motors from 11 ... 55 kW

- $\eta\approx 0.7$  ... 0.87 depending on load for motors from 0.55 ... 7.5 kW
- Calculation of the effective power P using the machnical output load P<sub>mech</sub> and the efficiency factor n at a certain load situation.

$$\begin{split} \mathsf{P} &= \mathsf{P}_{\mathsf{mech}} \; / \; \eta \\ \mathsf{e.g. at partial load P}_{\mathsf{mech}} &= 30 \; \mathsf{kW} \\ \mathsf{Result P} &= 33 \; \mathsf{kW} \end{split}$$

 Setting of the upper response value (pot P2) and the lower response value (pot P1) on scale.

Scale value = 10 x P/P<sub>max</sub> = 10 x 33 / 69.3  $\approx$  5

I. e. the potentiometer must be set to 5, that the device trips at 30 kW motor load. Setting tolerances may lead to slightly different values.

- 5.) Do the same procedure for the 2.) response value
- Set the unit to the required functions: closed or open circuit operation start-up delay operate delay

#### **Set-up Procedure**

## Variant 2

This method is recommended when it is possible to simulate the different load situations during set-up. In this case nothing has to be calculated. Turn the operate delay to min. The motor runs in underload while the Pot 1 is turned until the output relay switches. The same has to be done for overload. Now the unit is set accurately. Now adjust the operate delay and the start-up delay to the required values.

#### Variant 3

This method is the most simple one but not the most accurate. The operate delay is set to min. The motor is switched on and runs on nominal load. With both potentiometers the set points are searched by slowly turning the max. Pot from high to low value and the min. Pot from low to high value until the corresponding output relays switch. After that turn the Pot P2 slightly to the right side and the Pot 1 slightly to the left until the output relays reset. The unit is now set and responds if the load differs from the nominal value. Finally set the operate delay and start up delay to the required values.

E. DOLD & SÖHNE KG • D-78114 Furtwangen • PO Box 1251 • Telephone (+49) 77 23 / 654 - 0 • Telefax (+49) 77 23 / 654 - 356